## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7165-1477:103 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Mircom Technologies, 8111 Jane Street, Vaughan, Ontario L4K 4L7 Canada

Contact: Norma Kinitz 9905) 660-4655

**DESIGN**: Models FA-108, -124, - 156 or -188, with or without suffix -TS, fire alarm control units.

Local, auxiliary, remote station, non-coded, automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description

and operational considerations. System components:

PS-106-1, -106A -1 Power Supply PS-112-1 Power Supply

CC-100-1 Common Control Module DM-104, -108, DS-208 Zone Initiating w/display

PR-100 City Tie Module
TSM-100 Two Stage Module
TCM-100 Temporal Code Module
AM-108 Remote Annunciator Module
RM-104A Auxiliary Relay Module
WM-102 Walk Test Module

RATING: 120 VAC, 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances,

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally

compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to listee's Installation Instructions Manual for details.

07-21-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MARCH 15, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager